



KONGU ENGINEERING COLLEGE
(Autonomous)
PERUNDURAI, ERODE - 638 060, INDIA



Dr.P.Naveethakrishnan, M.E., Ph.D
Professor
BEE Certified Energy Auditor (Regd.No:EA3643)
Department of Mechanical Engineering

Phone : +91- 4294 - 226710
Mobile : 98429-50323
E-mail : pnkmech@gmail.com

Ref: KEC/EA/2021-22/103

17.04.2021

ENERGY AUDIT CERTIFICATE

This is to certify that, we have conducted an **Energy Audit in M/s.Paavai Engineering College**, Namakkal, Tamil Nadu on 15th April 2021. The audit team has identified energy saving measures and the summary of Energy Audit Process is given below.

S.No.	Description	Parameters
1	Annual Energy/ fuel Consumption	223660 kWh, 90000 lt diesel, 120 cylinders
2	Annual Energy Cost	Rs 79,33,790
3	Energy Savings due to the installation of 150 kW roof top solar PV plant (Life cycle time = 20 years)	223660 kWh
4	Proposed annual Energy Savings	Rs 14,53,790
5	Initial Investment Required	Rs 54,00,000
6	Payback period	3.7 years

Equipment/Systems Audited

Electrical Network
Inverter, UPS and Battery System
Lightings, Fans & Air Conditioning System
LPG Consumption for Cooking Application
Transportation and Gen-set fuel Consumption

Audited and Accounted for April 2020 to March 2021

Yours Truly


Dr.P.NAVANEETHAKRISHNAN
BEE Certified Energy Auditor
Regd. No: EA3643
5/83, Namakkalpalayam Road,
Chennimalai - 638 051, Erode Dt.



KONGU ENGINEERING COLLEGE

(Autonomous)

PERUNDURAI, ERODE - 638 060, INDIA



Dr.P.Naveethakrishnan, M.E., Ph.D

Professor

BEE Certified Energy Auditor (Regd.No:EA3643)

Department of Mechanical Engineering

Phone : +91- 4294 - 226710

Mobile : 98429-50323

E-mail : pnkmech@gmail.com

Ref: KEC/EA/2020-21/101

17.01.2020

ENERGY AUDIT CERTIFICATE

This is to certify that, we have conducted an **Energy Audit in M/s.Paavai Engineering College**, Namakkal, Tamil Nadu on 6th Jan 2020. The audit team has identified energy saving measures and the summary of Energy Audit Process is given below.

S.No.	Description	Parameters
1	Annual Energy/ fuel Consumption	8,44,691 kWh, 1,62,000 lt diesel, 1200 cylinders
2	Annual Energy Cost	Rs 1,61,99,692
3	Energy Savings due to a)the installation of 100 kW roof top solar PV plant(Life cycle time = 20 years) b)Energy efficiency in Transportation cooking and electricity usage	1,44,000 kWh 15,000 lt diesel + 20 cylinders
4	Proposed annual Energy Savings	Rs 19,39,000
5	Initial Investment Required	35,00,000
6	Payback period	1.8 years

Equipment/Systems Audited

Electrical Network

Inverter, UPS and Battery System

Lightings, Fans & Air Conditioning System

LPG Consumption for Cooking Application

Transportation and Gen-set fuel Consumption

Audited and Accounted for Jan 2019 to Dec 2019

Yours Truly

[Signature]
17/01/2020

Dr.P.NAVANEETHAKRISHNAN
BEE Certified Energy Auditor
Regd. No: EA3643
5/83, Namakkalpalavam Road.



KONGU ENGINEERING COLLEGE
(Autonomous)
PERUNDURAI, ERODE - 638 060, INDIA



Dr.P.Naveethakrishnan, M.E., Ph.D
Professor
BEE Certified Energy Auditor (Regd.No:EA3643)
Department of Mechanical Engineering

Phone : +91- 4294 - 226710
Mobile : 98429-50323
E-mail : pnkmech@gmail.com

Ref: KEC/EA/2019-20/105

10.01.2019

ENERGY AUDIT CERTIFICATE

This is to certify that, we have conducted an **Energy Audit in M/s.Paavai Engineering College,** Namakkal, Tamil Nadu on 7th Jan , 2019. The audit team has identified energy saving measures and the summary of Energy Audit Process is given below.


S.No.	Description	Parameters
1	Annual Energy/ fuel Consumption	883931 kWh, 1,69,500 lt diesel, 128 cylinders
2	Annual Energy Cost	Rs 1,69,42,252
3	Energy Savings due to the installation of 200 kW roof top solar PV plant (Life cycle time = 20 years)	2,88,000 kWh
4	Proposed annual Energy Savings	Rs 18,72,000
5	Initial Investment Required	Rs 70,00,000
6	Payback period	3.73 years

Equipment/Systems Audited

Electrical Network
Inverter, UPS and Battery System
Lightings, Fans & Air Conditioning System
LPG Consumption for Cooking Application
Transportation and Gen-set fuel Consumption

Audited and Accounted for Jan 2018 to Dec 2018

Yours Truly


Dr.P.NAVANEETHAKRISHNAN
BEE Certified Energy Auditor
Regd. No: EA3643
5/83, Namakkalpalayam Road,
Chennimalai - 638 051, Erode Dt.